



Product Evaluation

WIN2063 | 1215

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2063

Effective Date: December 1, 2015

Re-evaluation Date: October 2019

Product Name: Series 6814 Vinyl Tilt Double Hung Window, Impact Resistant

Manufacturer: Regency Plus, Inc.
2000 Locust Gap Highway
Mt. Carmel, PA 17851
(570) 339-3374

General Description:

System	Description	Label Rating	Design Pressure Rating (psf)
1	Series 6814 Vinyl Tilt Double Hung Window	R-PG50 40 X 84-H Wind Zone 4 Missile Level D	+50 / -50

Product Dimensions:

System	Overall Size (in.)	Sash Size Top (in.)	Sash Size Bottom (in.)
1	40 x 84	36.125 x 40	37.188 x 40.938

Product Identification (Certification Label on Window):

System		
1	Certification Agency	NAMI
	Manufacturer's Name or Code Name	Regency Plus, Inc.
	Product Name	6814 Tilt Vinyl Double Hung
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E 1886-13a/ASTM E 1996-12a Missile Level D

Impact Resistance:

System	Impact Resistant	Requirement
1	Yes	These products satisfy TDI's criteria for protection from windborne debris in the Inland I and Seaward zone. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

Installation:

System		
1	Type of Installation	The installation of this product must be in accordance with Drawing No. 08-02524 dated November 4, 2014. The drawing is signed and sealed by Luis R. Lomas, P.E. on November 05, 2014, sheets 1 of 4.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	

Note: Keep the manufacturer's installation instructions on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.